


CATALOG NUMBER: E-MCAFTJDD1001 FOR ONE 1000 WATT, M141 METAL HALIDE PULSE START LAMP


Line Voltage	120/277/347/480V
Regulation	
Line Volts	+/-10%
Line Watts	+/-10%
Frequency	60 Hz
Circuit Type	CWA
Power Factor (min)	90%
Insulation Class	H(180°)
Min. Ambient Starting Temp.	-20° F or -30° C

Line Voltage (Volts)	120	277	347	480
Line Current (Amps)				
Operating	9.0	3.9	3.2	2.4
Open Circuit	4.7	2.3	1.8	1.4
Starting	6.7	3.0	2.4	1.7
Input Watts (W)	1080	1080	1080	1080
Open Circuit Voltage (V)	421	421	421	421
Drop Out Voltage (V)	84	194	243	336
UL(1029) Bench Top Rise	B	C	C	B
Recommended Fuse (Amps)	20	10	10	6
HIGH POTENTIAL TEST (VOLTS)				
1Minute	2000			
2 Seconds	2500			
Open Circuit Voltage Test(volts)	385-475			
Short-Circuit Current Test (Amps)				
Secondary Current	5.2 - 6.4			
Input Current (Amps)	5.9 - 7.25	2.45 - 3.20	2.0 - 2.6	1.40 - 1.90




CORE AND COIL	
Dimension A (inches)	3.00
Dimension B (inches)	5.25
Weight (Lbs)	24.50
Lead Lengths (inches)	12

CAPACITOR




IGNITOR 356-AS-1001-MH

Ballast to Lamp Distance (BTL): 25 feet
(THERMAL PLASTIC CASE)
Max. case Temp: 110° C




WIRING DIAGRAM




BRACKET


CORE & COIL
MOUNTING BRACKET



KB47
Mounting bracket for
Core & Coil Ballasts
(2 brackets with thru bolts)



C-01
MOUNTING CLIP for round
case (Furnished as standard
with B suffix ballast)



I-01
MOUNTING CLIP for oval
case (Furnished as standard
with B suffix ballast)

Data is based upon tests performed by Industrias Sola Basic in a controlled environment and representative of relative performance. Actual Performance can vary depending on operating conditions. Specifications are subject to change without notice.



Certificate No. 006281



SOLA CANADA

LIGHTING & POWER

171 Ambassador Drive
Units 8 & 9
Mississauga, ON
L5T 2J1

Phone: 905-670-0746
Fax: 905-670-9689

www.solacanada.com